

Approval Number: 1702529
Test Report: LGC/WAT/2017/001



7th March 2017

EMO FRITE d.o.o
Mariborska 86,
3000 Celje,
Slovenia

Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

COATINGS, PAINTS & LININGS - FACTORY APPLIED PIPE & FITTINGS COATINGS.

5030

'R-4401, E-44131, E-4413, E-4414, E-4420, E440001, E441001, E440002, E441002, E-5402, E-5403, E-5404, E540001, E541001, E540002, E540003 & E541003'. Factory applied, grey-blue coloured enamel coatings. Apply as per manufacturer's instructions 'issue 02/2016' dated 05.10.2016. Cure for 6 minutes@840 °C. For use with water up to 85 °C. This material is only approved for the curing conditions that appear on the approval. If the cure conditions are varied from those specified on the approval then the material is not covered by the scope of the approval.

APPROVAL NUMBER: 1702529

APPROVAL HOLDER: EMO FRITE D.O.O

The Scheme reserves the right to review approval.
Approval 1702529 is valid between February 2017 and February 2022

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme